

MIAMI-DADE FIRE RESCUE DEPARTMENT - Inspection Report



FIRE PREVENTION DIVISION
9300 NW 41 STREET, DORAL, FLORIDA 33178
PHONE 786.331.4800 FAX 786.331.4801



PERMIT # 04121-00094

Business Address: (District 32)
 DCPS DR CARLOS J FINLAY ELEMENTARY
 SCHOOL
 851-851 SW 117 AVE
 MIAMI, FL 33174

Billing Address:
 DADE COUNTY PUBLIC SCHOOLS - DCPS
 1450 NE 2 AVE ROOM 602
 MIAMI, FL 33132

RESULT: Referred to State

Resulted Date: 8/30/21

Permit Type: Education / Public Licensed Educ. Facility.

Inspection Month: September

Inspector:
 FREDERIKA ROLLE
 (786) 331-4840
 fredericka.rolle@miamidade.gov

NOTICE OF VIOLATION AND ORDER TO CORRECT

The hazards noted herein are in violation of the Florida Fire Prevention Code and/or Miami-Dade County Code and are deemed to be threats to life safety and/or property. You are hereby ordered to comply with the corrective measures prescribed. Nothing in this report supersedes any previously written, still existing violations for this occupancy.

APPEALS

Any person who believes they were incorrectly issued a notice of violation or that the violation cited is not applicable to their occupancy classification or believes aggrieved by any action or decision of this code may appeal to the Miami-Dade County Fire Prevention and Safety Appeals Board by filing a written notice **within 30 days** of receiving the Notice of Violation and Order to Correct. The appeal request must be submitted in writing to the Secretary of the Board. Information on filing an appeal can be obtained on the web at: <http://www.miamidade.gov/fire/request-appeal.asp>. Filing of a written notice of appeal shall not stay the effect of any such action or decision which is the subject to the appeal. Section 14-36, Code of Miami-Dade County

Please Note: A Life Safety Permit required by Section 14-39, Code of Miami-Dade County, to operate the above named occupancy will be issued upon correction of all outstanding violations and payment of fees assessed. **Failure to obtain the required Life Safety Permit will result in enforcement actions including fines, citations, liens and/or orders to cease and desist operation.**

Viol.	Date Created	Comply by Date	Violation, Correction & Comments
Failure to comply with below violations will result in issuance of a citation			
1	3/22/21	4/21/21	<p>Violation: FFPC 7th Edition, NFPA 1:. 50.5.2.1 Commercial Cooking. Semi-Annual Inspection. Fire Suppression System. Failure to have cooking hood fire suppression system inspected..</p> <p>Correction: Have cooking hood fire suppression system inspected every 6 months by a licesned company, provide a current inspection and testing report; clear of any deficiencies or impairments..</p> <p>Comments: HAVE HOOD SYSTEM CHECKED SEMI ANNUAL BY A STATE CERTIFIED COMPANY.</p>
Violation Corrected on 08/30/2021			
2	8/30/21	9/29/21	<p>Violation: FFPC 7th Edition, NFPA 25:. 7.1.4 Fire Hose. Inspection. Failure to maintain fire hose(s)..</p> <p>Correction: Have fire protection contractor perform annual inspection and maintenance on fire hoses..</p> <p>Comments: HAVE FIRE PROTECTION COMPANY INSPECT AND SERVICE FIRE HOSE. YELLOW TAG.</p>



We would like feedback on your experience with your Life Safety Inspection. Please take a minute to complete our survey at:
http://bit.ly/mdfr_2tcSXHm

MIAMI-DADE FIRE RESCUE DEPARTMENT - Inspection Report

3	8/30/21	9/29/21	<p><u>Violation:</u> FFPC 7th Edition, NFPA 101:. 4.5.3.2 Unobstructed Egress. Failure to maintain an unobstructed means of egress..</p> <p><u>Correction:</u> Means of egress from all parts of the building shall be maintained free and unobstructed, in every occupied building or structure. Means of egress shall be accessible to the extent necessary to ensure reasonable safety for occupants having impaired mobility..</p> <p><u>Comments:</u> REMOVE STORAGE FRO MECHANICAL ROOMS 099,065.</p>
4	8/30/21	9/29/21	<p><u>Violation:</u> FFPC 7th Edition, NFPA 10:. 7.3.1.1 Fire Extinguisher. Maintenance. Failure to maintain fire extinguishers at intervals of not more than 1 year, at the time of hydro-static test, or when specifically indicated by an inspection discrepancy or electronic notification..</p> <p><u>Correction:</u> Have a licensed fire equipment company inspect, service, and tag the fire extinguisher(s)..</p> <p><u>Comments:</u> HAVE EXTINGUISHER SERVICED AND TAGGED BY LICENSED FIRE COMPANY RM 069B AND MECHANICAL ROOM 117C.</p>

CUSTOMER SIGNATURE

Title: Agency
Name:

Please Note: A life safety permit will be issued upon compliance of outstanding violations and payment of fees assessed . One (1) re-inspection will be performed at no additional cost. All subsequent re-inspections will be billed at one-half the original permit fee amount.



We would like feedback on your experience with your Life Safety Inspection .
Please take a minute to complete our survey at:
http://bit.ly/mdfr_2tcSXHm