

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Inspection report emailed to Marie Ort-Sanchez on 07/25/2022.

Digital thermometer model DPP400W was used during the inspection.
At the time of inspection no students were present due summer vacation.

Temperatures taken:
Bathroom shower head: 82°F.

Email Address(es): orthsanchez@dadeschools.net;
jaybolton@dadeschools.net;
jware@dadeschools.net;
ipalacio@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair

Observed stained and missing ceiling tiles in classrooms: 026 kindergarten, 027 kindergarten, 053 room, 056 science lab, 104 primary and 219 intermediate.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

.Observed lights out of order in 218 intermediate classrom, 085 female restroom and 086 male restroom.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Violation #16. Showers Water Temperatures

Observed water unable to reach 95°F. in the nursing's shower. Provide hot water in shower.

CODE REFERENCE: 16. Shower Water Temperature. 5(13)(h)1 SREF. Hot and cold water shall be provided at the shower. 5(16)(b)10 SREF and 468.3.5.8.3 FBC. Water shall be heated and the temperature at the shower head shall not exceed 110°F nor be less than 95°F.

Inspection Conducted By: Cesar Martinez (085423)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 7/25/2022

Inspector Signature:

Client Signature: