

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08767
Name of Facility: Finlay, Dr. Carlos J. El.
Address: 851 SW 117 Avenue
City, Zip: Miami 33184

Type: Public Schools
Owner: M-DCSB Food and Nutrition
Person In Charge: M-DCSB Food and Nutrition
PIC Email:

Phone: (786) 275-0400

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Reinspection
Inspection Date: 8/14/2023

Begin Time: 08:30 AM
End Time: 09:30 AM

Additional Information

FEMALES 274
MALES 282

CENSUS 556

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
NA 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	OUT 16. Showers Water Temperatures	NA 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

CM

Client Signature:

[Signature]

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Inspection report emailed to Marie Ort-Sanchez on 08/14/2023.

The inspection result is satisfactory because violation #5, #6 and #12 from previous inspection were corrected. Digital thermometer model DPP400W was used during the inspection.

Temperatures taken:

Bathroom shower head: 80°F.

Email Address(es): orthsanchez@dadeschools.net;
mwertz@dadeschools.net;
ipalacio@dadeschools.net;
wcabrera@dadeschools.net

Violations Comments

Violation #16. Showers Water Temperatures

Observed water unable to reach 95°F. in the nursing's shower. Provide hot water in shower. Work order in process. W.O # 4367098.

CODE REFERENCE: 16. Shower Water Temperature. 5(13)(h)1 SREF. Hot and cold water shall be provided at the shower. 5(16)(b)10 SREF and 468.3.5.8.3 FBC. Water shall be heated and the temperature at the shower head shall not exceed 110°F nor be less than 95°F.

Violation #18. Drinking Fountains

Observed two drinking fountains out of order by covered walkway. Repair drinking fountains. Work order in process. W.O # 4369022.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Cesar Martinez (085423)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 8/14/2023

Inspector Signature:

CM

Client Signature: